

**SUMMARY OF QUANTITIES
CONDUIT SYSTEM (LIGHTING)**

Precast Conc. Handholes (Std. Plate 8117)	4	Units
Light Standard Anchorage	4	Units
1-1/2" dia. Conduit	1200	Lin. Ft.
1-1/2" dia. Conduit End Caps	4	Units
Expansion Fittings	4	Units
Reinforcement Bars (EXPOSED COATED)	85	Lbs.

③ System to be grounded.
All material listed above is included in "CONDUIT SYSTEM LIGHTING"

BILL OF REINFORCEMENT FOR RAILING

BAR NO.	LENGTH	SHAPE	LOCATION
R521E	5'-6"	Bent	Light Std. - Long.
R522E	5'-6"	Bent	Light Std. - Long.
R523E	4'-6"	Bent	Light Std. - Long.
R524E	4'-6"	Bent	Light Std. - Long.
R525E	4'-6"	Bent	Light Std. - Long.
R526E	6'-10"	Bent	Light Std. - Long.
R527E	7'-4"	Bent	Light Std. - Vert.
R528E	6'-2"	Bent	Light Std. - Vert.

- ⑤ Welding permitted for alternate (X). Use stainless steel electrode-Type 308 for welding or repairing.
- ⑥ Welding permitted for alternate (Y). For procedures and electrodes refer to Spec. 2471.3J and Spec. 3339.

